



**OPTIONAL ANNUAL REPORT TEMPLATE**

<b>Drinking-Water System Number:</b>	260001604
<b>Drinking-Water System Name:</b>	Pelham Distribution System
<b>Drinking-Water System Owner:</b>	The Corporation of the Town of Pelham
<b>Drinking-Water System Category:</b>	Large Municipal
<b>Period being reported:</b>	January 1, 2013 to December 31, 2013

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ <input checked="" type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ <input checked="" type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Pelham Municipal Building 20 Pelham Town Square Fonthill, Ontario</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served: <input style="width: 50px;" type="text" value="19"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ <input type="checkbox"/> ] No [ <input type="checkbox"/> ]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ <input type="checkbox"/> ] No [ <input checked="" type="checkbox"/> ]</p>
---	---

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	Not applicable

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes [  ] No [  Not Applicable]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

The Corporation of the Town of Pelham operates a water distribution system which is supplied with treated water by the Regional Municipality of Niagara from the Welland Water Treatment Plant located at #4 Cross Street in Welland. The source of the water for the treatment plant is the Welland Recreational Waterway.

The treated water is transported to the Town by way of a 750mm diameter watermain to the Shoalts Drive Reservoir located at #5 Shoalts Drive in Fonthill. Water is distributed from the reservoir by way of a series of watermains and an elevated tank located at #177 Highway #20 West in Fonthill to lands within the designated service area.

The Pelham Distribution System is comprised of approximately 78.9 kilometers of watermains varying in size from 50mm to 400mm diameter. In addition there is a 300mm diameter watermain, 6.5 kilometers in length owned by the Regional Municipality of Niagara which is connected to the Pelham Distribution System and also distributes water to lands within the service area.

**List all water treatment chemicals used over this reporting period**

Not applicable

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment



Please provide a brief description and a breakdown of monetary expenses incurred

- (1) Replacement of cast iron watermain on Port Robinson Road from Pelham Street to Station Street, 433 metres, \$95,800.00
- (2) Replacement of cast iron watermain on Highland Avenue from Elizabeth Drive to Fonthill Cemetery entrance, 156 metres, \$69,200.00
- (3) Replacement of undersized watermain on Foss Road from Church Street to CP Railroad, 266 metres, \$113,000.00
- (4) Leak detection survey, \$12,400.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
	None to Report				

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw					
Treated					
Distribution	675	0 - 0	0 - 0	675	0 - 420

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity			
Chlorine	1385	.12 – 1.22	mg/l
Fluoride (If the DWS provides fluoridation)			

*NOTE: For continuous monitors use 8760 as the number of samples.*



**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
<b>Not Applicable</b>				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
<b>Plumbing</b>	<b>Exempt</b>			
<b>Distribution</b>	<b>12</b>	<b>0.00007 – 0.00035</b>	<b>Mg/l</b>	<b>0</b>

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				



<b>Aldrin + Dieldrin</b>				
<b>Atrazine + N-dealkylated metabolites</b>				
<b>Azinphos-methyl</b>				
<b>Bendiocarb</b>				
<b>Benzene</b>				
<b>Benzo(a)pyrene</b>				
<b>Bromoxynil</b>				
<b>Carbaryl</b>				
<b>Carbofuran</b>				
<b>Carbon Tetrachloride</b>				
<b>Chlordane (Total)</b>				
<b>Chlorpyrifos</b>				
<b>Cyanazine</b>				
<b>Diazinon</b>				
<b>Dicamba</b>				
<b>1,2-Dichlorobenzene</b>				
<b>1,4-Dichlorobenzene</b>				
<b>Dichlorodiphenyltrichloroethane (DDT) + metabolites</b>				
<b>1,2-Dichloroethane</b>				
<b>1,1-Dichloroethylene (vinylidene chloride)</b>				
<b>Dichloromethane</b>				
<b>2-4 Dichlorophenol</b>				
<b>2,4-Dichlorophenoxy acetic acid (2,4-D)</b>				
<b>Diclofop-methyl</b>				
<b>Dimethoate</b>				
<b>Dinoseb</b>				
<b>Diquat</b>				
<b>Diuron</b>				
<b>Glyphosate</b>				
<b>Heptachlor + Heptachlor Epoxide</b>				
<b>Lindane (Total)</b>				
<b>Malathion</b>				
<b>Methoxychlor</b>				
<b>Metolachlor</b>				
<b>Metribuzin</b>				
<b>Monochlorobenzene</b>				
<b>Paraquat</b>				
<b>Parathion</b>				
<b>Pentachlorophenol</b>				
<b>Phorate</b>				
<b>Picloram</b>				
<b>Polychlorinated Biphenyls(PCB)</b>				
<b>Prometryne</b>				



Simazine				
<b>THM</b> (NOTE: show latest annual average)	<b>Dec. 2013</b>	<b>39</b>	<b>micrograms/l</b>	<b>None</b>
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

**List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.**

<b>Parameter</b>	<b>Result Value</b>	<b>Unit of Measure</b>	<b>Date of Sample</b>
<b>THM</b>	<b>55.5</b>	<b>Micrograms/l</b>	<b>September 24, 2013</b>