

**OPTIONAL ANNUAL REPORT TEMPLATE**

<b>Drinking-Water System Number:</b>	260001604
<b>Drinking-Water System Name:</b>	Pelham Distribution System
<b>Drinking-Water System Owner:</b>	The Corporation of the Town of Pelham
<b>Drinking-Water System Category:</b>	Large Municipal
<b>Period being reported:</b>	January 1, 2010 to December 31, 2010

<p><b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [ x ] No [ ]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [ x ] No [ ]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Pelham Municipal Building 20 Pelham Town Square Fonthill, Ontario</p> </div>	<p><b><u>Complete for all other Categories.</u></b></p> <p>Number of Designated Facilities served:  <div style="border: 1px solid black; display: inline-block; padding: 2px 10px;">19</div> </p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [ ] No [ x ]</p> <p>Number of Interested Authorities you report to: <div style="border: 1px solid black; display: inline-block; padding: 2px 10px;">0</div></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [ ] No [ x ]</p>
-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report**

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	None

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?  
 Yes [ ] No [ NA ]



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method \_\_\_\_\_

**Describe your Drinking-Water System**

The Corporation of the Town of Pelham operates a water distribution system which is supplied with treated water by the Regional Municipality of Niagara from the Welland Water Treatment Plant located at #4 Cross Street in Welland. The source of the water for the treatment plant is the Welland Recreational Waterway.

The treated water is transported to the Town by way of a 750mm diameter watermain to the Shoalts Drive Reservoir located at #5 Shoalts Drive in Fonthill. Water is distributed from the reservoir by way of a series of watermains and an elevated tank located at #177 Highway #20 West in Fonthill to lands within the designated service area.

The Pelham Distribution System is comprised of approximately 75.3 kilometers of watermains varying in size from 50mm to 400mm diameter. In addition there is a 300mm diameter watermain, 6.7 kilometers in length owned by the Regional Municipality of Niagara which is connected to the Pelham Distribution System and also distributes water to lands within the service area.

**List all water treatment chemicals used over this reporting period**

Not applicable

**Were any significant expenses incurred to?**

- Install required equipment
- Repair required equipment
- Replace required equipment



Please provide a brief description and a breakdown of monetary expenses incurred

- (1) Replacement of cast iron watermain on Haist Street from Welland Road to Canboro Road, 1400 metres, \$295,000.00
- (2) Fire hydrant replacement program, replacement of 9 hydrants, \$61,700.00

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
June 8, 2010	Total coliforms	1	CFU/100mL	Flush and resample	June 14, 2010
June 15, 2010	No data, overgrown (NDOGN)	NA	NA	Flush and resample	June 21, 2010
Aug 10, 2010	Total coliforms	2	CFU/100mL	Flush and resample	Aug 18, 2010
	Fecal coliforms	1	CFU/100mL	Flush and resample	Aug 18, 2010
Aug 12, 2010	Total coliforms	27	CFU/100mL	Flush and resample	Aug 18, 2010
	Fecal coliforms	25	CFU/100mL	Flush and resample	Aug 18, 2010
Dec 23, 2010	Observation of potential contamination	NA	NA	Flush and sample	Dec 28, 2010

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw					
Treated					
Distribution	599	0 - 0	0 - 27	599	0 - 150

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)
Turbidity		
Chlorine	1040	0.11 – 1.41
Fluoride (If the DWS provides fluoridation)		

*NOTE: For continuous monitors use 8760 as the number of samples.*



*NOTE: Record the unit of measure if it is **not** milligrams per litre.*

**Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
<b>Not Applicable</b>				

**Summary of Inorganic parameters tested during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

\*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems

**Summary of lead testing under Schedule 15.1 during this reporting period**

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Number of Exceedances
Plumbing	NA exempt		
Distribution	NA exempt		

**Summary of Organic parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				



Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2,4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				
Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				



Prometryne				
Simazine				
THM (NOTE: show latest annual average)	Dec 14, 2010	28.3	Micrograms / litre	NA
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Trihalomethanes	61.5	Micrograms/litre	March 23, 2010
Trihalomethanes	58.8	Micrograms/litre	March 23, 2010
Trihalomethanes	61.6	Micrograms/litre	March 23, 2010