



OPTIONAL ANNUAL REPORT TEMPLATE

Drinking-Water System Number:	260001604
Drinking-Water System Name:	Pelham Distribution System
Drinking-Water System Owner:	The Corporation of the Town of Pelham
Drinking-Water System Category:	Large Municipal
Period being reported:	January 1, 2014 to December 31, 2014

<p><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></p> <p>Does your Drinking-Water System serve more than 10,000 people? Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Is your annual report available to the public at no charge on a web site on the Internet? Yes [<input checked="" type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <div style="border: 1px solid black; padding: 5px;"> <p>Pelham Municipal Building 20 Pelham Town Square Fonthill, Ontario</p> </div>	<p><u>Complete for all other Categories.</u></p> <p>Number of Designated Facilities served: <input style="width: 50px;" type="text" value="19"/></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes [<input type="checkbox"/>] No [<input type="checkbox"/>]</p> <p>Number of Interested Authorities you report to: <input style="width: 50px;" type="text" value="0"/></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes [<input type="checkbox"/>] No [<input checked="" type="checkbox"/>]</p>
---	---

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number
None	Not applicable

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?
Yes [] No [] Not Applicable



Indicate how you notified system users that your annual report is available, and is free of charge.

- Public access/notice via the web
- Public access/notice via Government Office
- Public access/notice via a newspaper
- Public access/notice via Public Request
- Public access/notice via a Public Library
- Public access/notice via other method _____

Describe your Drinking-Water System

The Corporation of the Town of Pelham operates a water distribution system which is supplied with treated water by the Regional Municipality of Niagara from the Welland Water Treatment Plant located at #4 Cross Street in Welland. The source of the water for the treatment plant is the Welland Recreational Waterway.

The treated water is transported to the Town by way of a 750mm diameter watermain to the Shoalts Drive Reservoir located at #5 Shoalts Drive in Fonthill. Water is distributed from the reservoir by way of a series of watermains and an elevated tank located at #177 Highway #20 West in Fonthill to lands within the designated service area.

The Pelham Distribution System is comprised of approximately 80.7 kilometers of watermains varying in size from 50mm to 400mm diameter. In addition there is a 300mm diameter watermain, 6.5 kilometers in length owned by the Regional Municipality of Niagara which is connected to the Pelham Distribution System and also distributes water to lands within the service area.

List all water treatment chemicals used over this reporting period

Not applicable

Were any significant expenses incurred to?

- Install required equipment
- Repair required equipment
- Replace required equipment



Please provide a brief description and a breakdown of monetary expenses incurred

- (1) Replacement of cast iron and asbestos cement watermain on Port Robinson Road from Station Street to 100 metres west of Rice Road, 725 metres, \$198,100.00**
- (2) Replacement of cast iron watermain on Highway 20 from Pelham Street to 130m east of Pelham Street, 145 metres, \$49,000.00**
- (3) Replacement of cast iron watermain on Highway 20 from Haist Street to Pinecrest, 340 metres, \$114,900.00**
- (4) Replacement of cast iron and asbestos cement watermain on Highway 20 from Haist Street to Lookout Street, 460 metres, \$155,700.00**
- (5) Replacement of cast iron watermain on Haist Street from Canboro Road to Highway 20, 203 metres, \$68, 600.00**
- (6) Bruce Wood watermain extension, Damude Drive to Oak Lane, 106 metres, \$35,300.00**

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date
Dec 15, 2014	Total Coliforms	1	Cfu/100ml	Flush and resample	Dec 22, 2014
Dec 16, 2014	Total Coliforms	1	Cfu/100ml	Flush and resample	Dec 22, 2014

Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.

	Number of Samples	Range of E.Coli Or Fecal Results (min #)-(max #)	Range of Total Coliform Results (min #)-(max #)	Number of HPC Samples	Range of HPC Results (min #)-(max #)
Raw					
Treated					
Distribution	719	0 - 0	0 - 1	719	0 - 249



Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

	Number of Grab Samples	Range of Results (min #)-(max #)	Unit of Measure
Turbidity			
Chlorine	1404	.16 – 1.20	mg/l
Fluoride (If the DWS provides fluoridation)			

NOTE: For continuous monitors use 8760 as the number of samples.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
Not Applicable				

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Antimony				
Arsenic				
Barium				
Boron				
Cadmium				
Chromium				
*Lead				
Mercury				
Selenium				
Sodium				
Uranium				
Fluoride				
Nitrite				
Nitrate				

*only for drinking water systems testing under Schedule 15.2; this includes large municipal non-residential systems, small municipal non-residential systems, non-municipal seasonal residential systems, large non-municipal non-residential systems, and small non-municipal non-residential systems.



Summary of lead testing under Schedule 15.1 during this reporting period

(applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)

Location Type	Number of Samples	Range of Lead Results (min#) – (max #)	Unit of Measure	Number of Exceedances
Plumbing	Exempt			
Distribution	8	0.00003 – 0.00018	Mg/l	0

Summary of Organic parameters sampled during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of Measure	Exceedance
Alachlor				
Aldicarb				
Aldrin + Dieldrin				
Atrazine + N-dealkylated metabolites				
Azinphos-methyl				
Bendiocarb				
Benzene				
Benzo(a)pyrene				
Bromoxynil				
Carbaryl				
Carbofuran				
Carbon Tetrachloride				
Chlordane (Total)				
Chlorpyrifos				
Cyanazine				
Diazinon				
Dicamba				
1,2-Dichlorobenzene				
1,4-Dichlorobenzene				
Dichlorodiphenyltrichloroethane (DDT) + metabolites				
1,2-Dichloroethane				
1,1-Dichloroethylene (vinylidene chloride)				
Dichloromethane				
2-4 Dichlorophenol				
2,4-Dichlorophenoxy acetic acid (2,4-D)				
Diclofop-methyl				
Dimethoate				
Dinoseb				
Diquat				
Diuron				
Glyphosate				
Heptachlor + Heptachlor Epoxide				



Lindane (Total)				
Malathion				
Methoxychlor				
Metolachlor				
Metribuzin				
Monochlorobenzene				
Paraquat				
Parathion				
Pentachlorophenol				
Phorate				
Picloram				
Polychlorinated Biphenyls(PCB)				
Prometryne				
Simazine				
THM (NOTE: show latest annual average)	Dec. 2014	33.9	micrograms/l	None
Temephos				
Terbufos				
Tetrachloroethylene				
2,3,4,6-Tetrachlorophenol				
Triallate				
Trichloroethylene				
2,4,6-Trichlorophenol				
2,4,5-Trichlorophenoxy acetic acid (2,4,5-T)				
Trifluralin				
Vinyl Chloride				

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Not Applicable			